



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Poulsbo Elementary

School Code: 2026

School District Name: North Kitsap

Address: 18531 Noll Rd NE, Poulsbo WA 98370

County: Kitsap

Number of Samples Collected: 75

Date Collected: 11/01/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	16228				<1	11/14/2018	
2.	16229	First Draw	Bubbler	Rm 17	<1	11/14/2018	
3.	16230	First Draw	Tap	Rm 17	1	11/14/2018	
4.	16231	First Draw	Bubbler	Computer Lab	1	11/14/2018	
5.	16232	First Draw	Tap	Computer Lab	3	11/14/2018	
6.	16233	First Draw	Bubbler	Rm 18	1	11/14/2018	
7.	16234	First Draw	Tap	Rm 18	1	11/14/2018	
8.	16235	First Draw	Bubbler	Rm 19	<1	11/14/2018	Very irregular function
9.	16236	First Draw	Tap	Rm 19	<1	11/14/2018	
10.	16237	First Draw	Bubbler	Rm 20	<1	11/14/2018	
11.	16238	First Draw	Tap	Rm 20	<1	11/14/2018	
12.	16239	First Draw	Bubbler	Rm 21	<1	11/14/2018	
13.	16240	First Draw	Tap	Rm 21	1	11/14/2018	
14.	16241	First Draw	Tap	Lab C Common	1	11/14/2018	
15.	16242	First Draw	Bubbler	In between Lab C and Lab D	<1	11/14/2018	Left
16.	16243	First Draw	Bubbler	In between Lab C	<1	11/14/2018	Right

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
				and Lab D			
17.	16244	First Draw	Bubbler	Rm 22	<1	11/14/2018	
18.	16245	First Draw	Tap	Rm 22	<1	11/14/2018	
19.	16246	First Draw	Bubbler	Rm 23	<1	11/14/2018	Lower function
20.	16247	First Draw	Tap	Rm 23	2	11/14/2018	Lower function
21.	16248	First Draw	Bubbler	Rm 24	1	11/14/2018	
22.	16249	First Draw	Tap	Rm 24	1	11/14/2018	
23.	16250	First Draw	Bubbler	Rm 1	1	11/14/2018	
24.	16251	First Draw	Tap	Rm 1	1	11/14/2018	Right side
25.	16252	First Draw	Tap	Rm 1	2	11/14/2018	Left side
26.	16253	First Draw	Bubbler	Rm 2	<1	11/14/2018	
27.	16254	First Draw	Tap	Rm 2	1	11/14/2018	Right side
28.	16255	First Draw	Tap	Rm 2	3	11/14/2018	Left side
29.	16256	First Draw	Bubbler	Rm 3	3	11/14/2018	
30.	16257	First Draw	Tap	Rm 3	2	11/14/2018	
31.	16258	First Draw	Bubbler	Rm 4/5	1	11/14/2018	
32.	16259	First Draw	Tap	Rm 4/5	<1	11/14/2018	
33.	16260	First Draw	Bubbler	Rm 6	<1	11/14/2018	
34.	16261	First Draw	Tap	Rm 6	1	11/14/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
35.	16262	First Draw	Bubbler	Rm 7	1	11/14/2018	
36.	16263	First Draw	Tap	Rm 7	1	11/14/2018	
37.	16264	First Draw	Bubbler	Rm 8	<1	11/14/2018	
38.	16265	First Draw	Tap	Rm 8	1	11/14/2018	
39.	16266	First Draw	Bubbler	Rm 9	1	11/14/2018	
40.	16267	First Draw	Tap	Rm 9	1	11/14/2018	
41.	16268	First Draw	Tap	Lab A Common	2	11/14/2018	
42.	16269	First Draw	Bubbler	Between Lab A and Lab B	<1	11/14/2018	Left
43.	16270	First Draw	Bubbler	Between Lab A and Lab B	<1	11/14/2018	Right
44.	16271	First Draw	Bubbler	Rm 10	<1	11/14/2018	
45.	16272	First Draw	Tap	Rm 10	<1	11/14/2018	
46.	16273	First Draw	Bubbler	Rm 11	1	11/14/2018	
47.	16274	First Draw	Tap	Rm 11	1	11/14/2018	
48.	16275	First Draw	Bubbler	Rm 12	1	11/14/2018	
49.	16276	First Draw	Tap	Rm 12	1	11/14/2018	
50.	16277	First Draw	Bubbler	Rm 15	1	11/14/2018	
51.	16278	First Draw	Tap	Rm 15	1	11/14/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
52.	16279	First Draw	Bubbler	Rm 16	<1	11/14/2018	
53.	16280	First Draw	Tap	Rm 16	1	11/14/2018	
54.	16281	First Draw		Kitchen	1	11/14/2018	Only water
55.	16282	First Draw	Bubbler	Outside Kitchen	<1	11/14/2018	
56.	16283	First Draw	Tap	Music	60	11/14/2018	
57.	16284	First Draw	Bubbler	Portable I	<1	11/14/2018	
58.	16285	First Draw	Tap	Portable I	<1	11/14/2018	
59.	16286	First Draw	Bubbler	Portable H	1	11/14/2018	
60.	16287	First Draw	Tap	Portable H	26	11/14/2018	
61.	16288	First Draw	Tap	Portable A	<1	11/14/2018	
62.	16289	First Draw	Tap	Portable B	<1	11/14/2018	
63.	16290	First Draw	Tap	Portable C	<1	11/14/2018	
64.	16291	First Draw	Tap	Portable D	<1	11/14/2018	
65.	16292	First Draw		Portable E	5	11/14/2018	
66.	16293	First Draw	Tap	Portable E	1	11/14/2018	
67.	16294	First Draw	Bubbler	Portable F	5	11/14/2018	
68.	16295	First Draw	Tap	Portable F	<1	11/14/2018	
69.	16296	First Draw	Bubbler	Portable G	<1	11/14/2018	
70.	16297	First Draw	Tap	Portable G	3	11/14/2018	
71.	16298	First Draw	Bubbler	Outdoor bubblers	<1	11/14/2018	Left

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
72.	16299	First Draw	Bubbler	Outdoor bubblers	<1	11/14/2018	Right
73.	16300	First Draw	Tap	Library Office	18	11/14/2018	
74.	16301	First Draw			<1	11/14/2018	
75.	16302	First Draw	Tap	Nurse	<1	11/14/2018	Restroom only water